


TO ALARM DEVICES: 14 BELLS.
 DEVICE LOCATIONS: ORIGINAL A/E
 DRAWINGS E3, E4, AND E5.
 WIRE NUMBERS: 1ST DIGIT IS OLD
 TB No. 2ND & 3RD ARE LAST
 TWO DIGITS OF ZONE No.



HOLD FOR EXISTING CONDITION INFORMATION

2 3RD FLOOR ALARM DEVICES
 SCALE: NONE

FROM INITIATING DEVICES.
 DEVICE LOCATIONS: ORIGINAL A/E
 DRAWINGS E3, E4, AND E5.
 WIRE NUMBERS: 1ST DIGIT IS OLD
 TB No. 2ND & 3RD ARE LAST
 TWO DIGITS OF ZONE No.



HOLD FOR EXISTING CONDITION INFORMATION

3 3RD FLOOR INITIATING DEVICES
 SCALE: NONE

SYMBOLS

- ② PYROTROXICS MODEL
 DI-3 IONIZATION SMOKE
 DETECTOR

NOTES

- SMOKE DETECTORS ARE PYROTROXICS IONIZATION TYPE, MODEL DI-3
- CONNECT THE SMOKE DETECTOR IN THE 3RD FLOOR ELEVATOR LOBBY
 TO THE 2ND FLOOR ELEVATOR LOBBY SMOKE DETECTOR AND ON TO
 THE FAC IN RM. 033. REFER TO 48062E01 FOR WIRING DETAILS.

REFERENCE DRAWINGS

- 4862E011 BLDG 62 FIRE ALARM SYSTEM
 SYS 3 WIRING DIAGRAM
- 4862E024 BLDG 62 FIRE ALARM SYSTEM
 TX 113, 114 ZONE WIRING DIAGRAM
- 4862E057 BLDG 62 FIRE ALARM SYSTEM
 LOGIC DIAGRAM
- 4862E058 BLDG 62 FIRE ALARM SYSTEM
 1ST FLOOR & GSA INIT / ALARM DEVICES
- 4862E059 BLDG 62 FIRE ALARM SYSTEM
 2ND FLOOR INIT / ALARM DEVICES
- 4862E060 BLDG 62 FIRE ALARM SYSTEM
 3RD FLOOR INIT / ALARM DEVICES
- 4862E061 BLDG 62 FIRE ALARM SYSTEM
 ELEV & MISC INIT / ALARM DEVICES

THIS DRAWING — 6. 4862E060

DISTRIBUTION LIST:
 2-ELECTRIC SHOP B76 (FILE 1 & 4)
 1-BROJ (FILE 10)
 1-STICK FILE BROJ
 ORIGINAL-FLAT FILE B90F

Unfinished
 04/18/01

62 FIRE ALARM SYSTEM
 3RD FLOOR INIT / ALARM DEVICES
 WIRING DIAGRAM

UNIVERSITY OF CALIFORNIA
 LAWRENCE BERKELEY NATIONAL LABORATORY
 FACILITIES DEPARTMENT

DESIGNED BY	CMS	DATE	05/18/01
CHECKED BY	MOJ		
APPROVED BY	MOJ		
DESIGN FILE NO.	00012221		
SCALE	As Noted		
DRAWING NO.	4862E060_	SHEET	
PROJECT NO.	308021	OF	